

CERTIFICATE



SKZ - Testing GmbH awards the following company

REHAU Industries SE & Co. KG

Ytterbium 4

DE-91058 Erlangen

Production site: REHAU Industries SE & Co. KG, DE-94234 Viechtach

the right to use the SKZ-mark



A 108

for the following plastic products

**Heating pipes made of PE-Xa, without or with oxygen barrier,
1-, 3- and 4-layer, dimension group 1 ($d_n \leq 63$ mm)**

Structure	Dimension	Application class	
		4	5
1-layer	15 x 2.5 mm, 22 x 3.0 mm	10 bar	10 bar
1-layer	12 x 2.0 mm	-	10 bar
1-layer	16 x 2.0 mm	-	8 bar
1-layer	18 x 2.0 mm, 20 x 2.0 mm, 25 x 2.3 mm, 32 x 2.9 mm	-	6 bar
3-layer	16 x 2.0 mm	10 bar	8 bar
3-layer	16 x 1.5 mm	8 bar	6 bar
3-layer	12 x 1.1 mm	8 bar	-
3-layer	12 x 2.0 mm, 17 x 2.0 mm, 18 x 2.0 mm, 20 x 2.0 mm, 25 x 2.3 mm, 32 x 2.9 mm	6 bar	6 bar
3-layer	10.1 x 1,1 mm, 14 x 1.5 mm	-	6 bar
4-layer	16 x 1.5 mm	8 bar	-

according to SKZ-Specification for Tests and Inspection **HR 3.2:2022-10.**

Users of the SKZ-mark are obliged to observe the required regulations for the production and testing of these products.

Date of initial certification: 27 June 1977

Date of expiry: 20 January 2031

Würzburg, 21 January 2026



i. V. 
Dipl.-Ing. (FH) Michael Klute
Deputy Head of Certification Body

The original language of this certificate is German. In case of doubt, the German version is obligatory.

SKZ - Testing GmbH, Friedrich-Bergius-Ring 22, 97076 Würzburg, Germany | Tel. +49 931 4104-0, testing@skz.de, www.skz.de
The Certification Body of SKZ - Testing GmbH is accredited by DAkKS according to DIN EN ISO/IEC 17065:2013 under the number D-ZE-19033-01.