

SKZ - Testing GmbH awards the following company

**aquatherm GmbH**  
**Biggen 5**  
**DE-57439 Attendorn**

Production site: aquatherm GmbH, DE-57439 Attendorn

the right to use the SKZ-mark



**A 314**

for the following plastic products

**Fibre multilayer pipes made of PP-R/PP-R GF/PP-R, SDR 7.4**  
**Dimension groups 1 ( $d_n \leq 63$  mm) and 2 ( $75 \leq d_n \leq 160$  mm)**

Dimensions	Application class / design pressure			
	1	2	4	5
20 x 2.8 mm, 25 x 3.5 mm, 32 x 4.4 mm, 40 x 5.5 mm, 50 x 6.9 mm, 63 x 8.6 mm, 75 x 10.3 mm, 90 x 12.3 mm, 110 x 15.1 mm, 125 x 17.1 mm, 160 x 21.9 mm	8 bar	8 bar	10 bar	6 bar

Trade name: aquatherm green pipe SDR 7,4 MF

according to SKZ-Specification for Tests and Inspection **HR 3.28:2021-08**.

Users of the SKZ-mark are obliged to observe the required regulations for the production and testing of these products.

Date of initial certification: 27 July 2000

Date of expiry: 7 May 2031

Würzburg, 8 May 2026



i.v. 

Dipl.-Ing. (FH) Katja Müller  
 Head of Certification Body

The original language of this certificate is German. In case of doubt, the German version is obligatory.

SKZ - Testing GmbH, Friedrich-Bergius-Ring 22, 97076 Würzburg, Germany | Tel. +49 931 4104-0, testing@skz.de, www.skz.de  
 The Certification Body of SKZ - Testing GmbH is accredited by DAkKS according to DIN EN ISO/IEC 17065:2013 under the number D-ZE-19033-01.