

# CERTIFICATE



**SKZ - Testing GmbH** awards the following company

**Schütz GmbH & Co. KGaA**  
**Schützstraße 12**  
**DE-56242 Selters**

Production site: Schütz GmbH & Co. KGaA, DE-56235 Ransbach-Baumbach

the right to use the **SKZ**-mark



**A 342**

for the following plastic products

**Heating pipes made of PE-Xa with oxygen barrier, 5-layer**  
**Dimension group 1 ( $\leq \varnothing 63$  mm)**

Dimension	Application class	
	4	5
$\varnothing 12 \times 1.5$ mm, $\varnothing 16 \times 1.8$ mm, $\varnothing 16 \times 2.0$ mm, $\varnothing 17 \times 2.0$ mm, $\varnothing 18 \times 2.0$ mm	8 bar	6 bar
$\varnothing 14 \times 1.5$ mm, $\varnothing 16 \times 1.5$ mm, $\varnothing 20 \times 1.9$ mm, $\varnothing 20 \times 2.0$ mm, $\varnothing 25 \times 2.3$ mm	6 bar	4 bar
$\varnothing 14 \times 2.0$ mm, $\varnothing 16 \times 2.2$ mm	10 bar	8 bar

Trade name: duo-flex PE-Xa and duo-flex PE-Xa Klett

according to **SKZ**-Specification for Tests and Inspection **HR 3.2:2022-10**.

Users of the **SKZ**-mark are obliged to observe the required regulations for the production and testing of these products.

Date of initial certification: 10 June 2002

Date of expiry: 19 May 2029

Würzburg, 20 May 2024



i. A.

Dipl.-Ing. (FH) Michael Klute  
Deputy Head of Certification Body

The original language of this certificate is German. In case of doubt, the German version is obligatory.

SKZ - Testing GmbH, Friedrich-Bergius-Ring 22, 97076 Würzburg, Germany | Tel. +49 931 4104-0, testing@skz.de, www.skz.de  
The Certification Body of SKZ - Testing GmbH is accredited by DAkkS according to DIN EN ISO/IEC 17065:2013 under the number D-ZE-19033-01.