

CERTIFICATE



SKZ - Testing GmbH awards the following company

Solin S.A.
Production of Plastic Tubes
12, Souliou Str. N. Chalkidon
GR-14343 Athens

Production site: Solin S.A., GR-38500 Volos

the right to use the SKZ-mark



A 344

for the following plastic products

**Heating pipes made of PE-RT Type I without or with oxygen barrier,
1-, 3-, or 5-layer, dimension group 1 ($d_n \leq 63$ mm)**

Structure	Dimension	Application class	
		4	5
1-layer	10 x 1.5 mm, 12 x 2 mm, 14 x 2 mm	10 bar	8 bar
	8 x 1.1 mm, 10 x 1.3 mm, 10 x 1.4 mm, 15 x 2 mm, 18 x 2.5 mm, 22 x 3 mm	10 bar	6 bar
	8 x 1 mm, 12 x 1.5 mm, 16 x 2 mm, 17 x 2 mm, 18 x 2 mm	8 bar	6 bar
	14.7 x 1.45 mm, 20 x 2 mm, 28 x 3 mm	6 bar	4 bar
3-layer	10 x 1.5 mm, 12 x 2 mm, 14 x 2 mm	10 bar	8 bar
	8 x 1.1 mm, 10 x 1.3 mm, 10 x 1.4 mm, 15 x 2 mm, 22 x 3 mm	10 bar	6 bar
	8 x 1 mm, 12 x 1.5 mm, 16 x 2 mm, 17 x 2 mm, 18 x 2 mm	8 bar	6 bar
	20 x 2 mm, 28 x 3 mm	6 bar	4 bar
5-layer	12 x 2 mm	10 bar	8 bar
	8 x 1.1 mm, 10 x 1.4 mm, 10 x 1.5 mm, 14 x 2 mm, 15 x 2 mm, 22 x 3 mm	8 bar	6 bar
	8 x 1 mm, 10 x 1.3 mm, 12 x 1.5 mm, 16 x 2 mm,	6 bar	4 bar
	17 x 2 mm, 18 x 2 mm, 20 x 2 mm, 28 x 3 mm		

according to **SKZ-Specification for Tests and Inspection HR 3.16:2024-02.**

Users of the **SKZ**-mark are obliged to observe the required regulations for the production and testing of these products.

Date of initial certification: 21 December 1999

Date of expiry: 18 May 2030

Würzburg, 19 May 2025



i. A. 
Dipl.-Ing. (FH) Michael Klute
Deputy Head of Certification Body

The original language of this certificate is German. In case of doubt, the German version is obligatory.

SKZ - Testing GmbH, Friedrich-Bergius-Ring 22, 97076 Würzburg, Germany | Tel. +49 931 4104-0, testing@skz.de, www.skz.de
The Certification Body of SKZ - Testing GmbH is accredited by DAkkS according to DIN EN ISO/IEC 17065:2013 under the number D-ZE-19033-01.