

# CERTIFICATE



**SKZ - Testing GmbH** awards the following company

**Valsir S.p.A.**  
**Loc. Merlaro, 2**  
**25078 Vestone (BS)**  
**Italy**

Production site: Valsir S.p.A., 25079 Vobarno (BS), Italy

the right to use the **SKZ**-mark



**A 364**

for the following plastic products

**Heating Pipes made of crosslinked polyethylene PE-Xb  
with oxygen barrier layer**

Dimension	Application class	
	4	5
Ø 12 x 2 mm / Ø 14 x 2 mm / Ø 15 x 2.5 mm / Ø 16 x 2.2 mm / Ø 20 x 2.8 mm	---	10 bar
Ø 16 x 2 mm / Ø 17 x 2 mm / Ø 18 x 2 mm	10 bar	8 bar
Ø 20 x 2 mm	8 bar	---
Ø 25 x 2.3 mm	8 bar	6 bar

Trade name: **THERMOLINE**

according to **SKZ-Specification for Tests and Inspection HR 3.2:2022-10**.

Users of the **SKZ**-mark are obliged to observe the required regulations for the production and testing of these products.

Date of initial certification: 6 October 2003

Date of expiry: 4 October 2028

Würzburg, 6 October 2023



i.A.

**Dipl.-Ing. (FH) Nancy Wytrykus**  
Deputy Head of Certification Body

The original language of this certificate is German. In case of doubt, the German version is obligatory.

SKZ - Testing GmbH, Friedrich-Bergius-Ring 22, 97076 Würzburg, Germany | Tel. +49 931 4104-0, testing@skz.de, www.skz.de  
The Certification Body of SKZ - Testing GmbH is accredited by DAkkS according to DIN EN ISO/IEC 17065:2013 under the number D-ZE-19033-01.