

*SKZ - Testing GmbH awards the following company*

**Interplast S.A. Piping Systems**  
**10 th Klm National Road**  
**Thessaloniki-Katerini**  
**GR-57400 Sindos Thessaloniki**

*Production site: Interplast S.A. Piping Systems, GR-69100 Komotini*

*the right to use the SKZ-mark*



**A 401**

*for the following plastic products*

**Heating pipes made of PE-RT Type I, 3-layer,  
dimension group 1 ( $d_n \leq 63$  mm)**

Dimension	Application class	
	4	5
12 x 2.0 mm, 14 x 2.0 mm, 15 x 2.5 mm, 16 x 2.2 mm, 20 x 2.8 mm	10 bar	6 bar
16 x 2.0 mm, 17 x 2.0 mm, 18 x 2.0 mm	8 bar	6 bar
20 x 2.0 mm, 25 x 2.3 mm	6 bar	4 bar

*Trade name: Como floor*

*according to SKZ-Specification for Tests and Inspection **HR 3.16:2024-02**.*

*Users of the SKZ-mark are obliged to observe the required regulations for the production and testing of these products.*

*Date of initial certification: 24 June 2005*

*Date of expiry: 3 May 2030*

*Würzburg, 4 May 2025*



i. A.   
Dipl.-Ing. (FH) Michael Klute  
Deputy Head of Certification Body

The original language of this certificate is German. In case of doubt, the German version is obligatory.

SKZ - Testing GmbH, Friedrich-Bergius-Ring 22, 97076 Würzburg, Germany | Tel. +49 931 4104-0, testing@skz.de, www.skz.de  
The Certification Body of SKZ - Testing GmbH is accredited by DAkkS according to DIN EN ISO/IEC 17065:2013 under the number D-ZE-19033-01.