

CERTIFICATE



SKZ - Testing GmbH awards the following company

THERMACOME
7 boulevard Willy Stein
ZA La Croix Vincent
50240 SAINT JAMES
FRANCE

Production site: ACOME Building Devision, FR-50140 MORTAIN

*the right to use the **SKZ**-mark*



A 443

for the following plastic products

Heating pipes made of crosslinked polyethylene PE-Xc

Application class 4 | Application pressure 8 bar | Application class 5 | Application pressure 6 bar
Ø 12 x 1,1 mm | Ø 16 x 1,5 mm | Ø 20 x 2,0 mm

Application class 4 + 5 | Application pressure 10 bar
Ø 12 x 2,0 mm | Ø 14 x 2,0 mm

Application class 4 | Application pressure 10 bar | Application class 5 | Application pressure 8 bar
Ø 16 x 2,0 mm | Ø 17 x 2,0 mm | Ø 18 x 2,0 mm | Ø 25 x 3,2 mm

*according to **SKZ**-Specification for Tests and Inspection **HR 3.2:2015-04**.*

*Users of the **SKZ**-mark are obliged to observe the required regulations for the production and testing of these products.*

Date of initial certification: 8 November 2006

Date of expiry: 11 April 2027

Würzburg, 31 May 2023/



i.V.

Dipl.-Ing. Hans-Peter Krause
Head of Certification Body

The original language of this certificate is German. In case of doubt, the German version is obligatory.

SKZ - Testing GmbH, Friedrich-Bergius-Ring 22, 97076 Würzburg, Germany | Tel. +49 931 4104-0, testing@skz.de, www.skz.de
The Certification Body of SKZ - Testing GmbH is accredited by DAkkS according to DIN EN ISO/IEC 17065:2013 under the number D-ZE-19033-01.