

CERTIFICATE



SKZ - Testing GmbH awards the following company

Pipex Extrusion S.L.U.
P.I. Manzanares
Calle D, Plot R-189
ES-13200 Manzanares, Ciudad Real

Production site: Pipex Extrusion S.L.U., ES-13200 Manzanares, Ciudad Real

the right to use the **SKZ**-mark



A 464

for the following plastic products

**Heating pipes made of PE-Xa, without or with oxygen barrier,
1-, and 3-layer, dimension group 1 ($d_n \leq 63$ mm)**

Structure	Dimension	Application class	
		4	5
1-layer	12 x 2.0 mm, 16 x 2.2 mm, 20 x 2.8 mm, 25 x 3.5 mm, 32 x 4.4 mm	10 bar	10 bar
1-layer	16 x 1.8 mm	10 bar	8 bar
1-layer	12 x 1.1 mm, 16 x 1.5 mm, 20 x 1.9 mm, 32 x 2.9 mm	8 bar	6 bar
3-layer	14 x 2.0 mm	10 bar	10 bar
3-layer	16 x 2.0 mm, 17 x 2.0 mm	10 bar	8 bar
3-layer	18 x 2.0 mm, 20 x 2.0 mm	8 bar	6 bar
3-layer	25 x 2.3 mm	6 bar	6 bar

according to **SKZ**-Specification for Tests and Inspection **HR 3.2:2022-10**.

Users of the **SKZ**-mark are obliged to observe the required regulations for the production and testing of these products.

Date of initial certification: 20 November 2007

Date of expiry: 29 October 2030

Würzburg, 30 October 2025



i. V. Michael Klute
Dipl.-Ing. (FH) Michael Klute
Deputy Head of Certification Body

The original language of this certificate is German. In case of doubt, the German version is obligatory.

SKZ - Testing GmbH, Friedrich-Bergius-Ring 22, 97076 Würzburg, Germany | Tel. +49 931 4104-0, testing@skz.de, www.skz.de
The Certification Body of SKZ - Testing GmbH is accredited by DAkkS according to DIN EN ISO/IEC 17065:2013 under the number D-ZE-19033-01.