

*SKZ - Testing GmbH awards the following company*

**aquatherm GmbH**  
**Biggen 5**  
**DE-57439 Attendorn**

*Production site: aquatherm GmbH, DE-57439 Attendorn*

*the right to use the **SKZ**-mark*



**A 644**

*for the following plastic products*

**Fibre multilayer pipes made of PP-RCT/PP-RCT GF/PP-RCT, SDR 7.4 and 9  
 Group 1 ( $\leq \varnothing$  63 mm), Group 2 ( $\varnothing$  75 – 160 mm), Group 3 ( $>$  160 mm)**

Dimensionen		Application class	
		1	2
SDR 7.4	20 x 2.8 mm, 25 x 3.5 mm	8 bar	8 bar
SDR 9	32 x 3.6 mm, 40 x 4.5 mm, 50 x 5.6 mm, 63 x 7.1 mm, 75 x 8.4 mm, 90 x 10.1 mm, 110 x 12.3 mm, 125 x 14.0 mm, 250 x 27.9 mm, 315 x 35.2mm	8 bar	8 bar

*Trade name: green pipe SDR9 MF-RP  
 green pipe SDR 7,4 MF-RP*

*according to **SKZ**-Specification for Tests and Inspection **HR 3.28:2021-08**.*

*Users of the **SKZ**-mark are obliged to observe the required regulations for the production and testing of these products.*

*Date of initial certification: 1 October 2013*

*Date of expiry: 4 October 2028*

*Würzburg, 17 October 2025/*



*i.v.*   
**Dipl.-Ing. (FH) Katja Müller**  
**Head of Certification Body**

The original language of this certificate is German. In case of doubt, the German version is obligatory.

SKZ - Testing GmbH, Friedrich-Bergius-Ring 22, 97076 Würzburg, Germany | Tel. +49 931 4104-0, testing@skz.de, www.skz.de  
 The Certification Body of SKZ - Testing GmbH is accredited by DAkS according to DIN EN ISO/IEC 17065:2013 under the number D-ZE-19033-01.