

SKZ - Testing GmbH awards the following company

FV-Plast, a.s.
Kozovazská 1049/3
CZ-25088 CELÁKOVICE

Production site: FV-Plast, a.s., CZ-25088 CELÁKOVICE

the right to use the **SKZ**-mark



A 674

for the following plastic products

**Heating pipes made of PE-RT Type II, with oxygen barrier,
5-layer, dimension group 1 ($d_n \leq 63$ mm)**

Dimension	Application class	
	4	5
16 x 2.0 mm, 17 x 2.0 mm	8 bar	6 bar
18 x 2.0 mm	6 bar	6 bar
20 x 2.0 mm	6 bar	4 bar

according to **SKZ**-Specification for Tests and Inspection **HR 3.16:2024-02**.

Users of the **SKZ**-mark are obliged to observe the required regulations for the production and testing of these products.

Date of initial certification: 20 April 2015

Date of expiry: 1 April 2031

Würzburg, 11 May 2026/



i. V.
Dipl.-Ing. (FH) Katja Müller
Head of Certification Body