

SKZ - Testing GmbH awards the following company

EGYPTIAN GERMAN Co. for Construction Industries S.A.E.
53 El-Manil Street, 7th floor
EG-CAIRO

Production site: EGYPTIAN GERMAN Co. for Construction Industries S.A.E.
EG-6th OCTOBER CITY, GIZA

the right to use the SKZ-mark



A 701

for the following plastic products

Pressure pipes made of PP-R, SDR 6
Dimension group 1 ($d_n \leq 63$ mm)
Application classes 1 and 4 with design pressure 10 bar
Application class 2 with design pressure 8 bar
Application class 5 with design pressure 6 bar

Trade name: SH smart Home

*according to SKZ-Specification for Tests and Inspection **HR 3.10:2016-03**.*

Users of the SKZ-mark are obliged to observe the required regulations for the production and testing of these products.

Date of initial certification: 15 October 2015

Date of expiry: 12 August 2030

Würzburg, 13 August 2025



i. A. Michael Klute

Dipl.-Ing. (FH) Michael Klute
Deputy Head of Certification Body

The original language of this certificate is German. In case of doubt, the German version is obligatory.

SKZ - Testing GmbH, Friedrich-Bergius-Ring 22, 97076 Würzburg, Germany | Tel. +49 931 4104-0, testing@skz.de, www.skz.de
The Certification Body of SKZ - Testing GmbH is accredited by DAkkS according to DIN EN ISO/IEC 17065:2013 under the number D-ZE-19033-01.