

# CERTIFICATE



SKZ - Testing GmbH awards the following company

**Auray Managing, S.L.U.**  
**C/Mercaders 4**  
**ES-08184 Palau Solita / Plegamans**

Production site: Auray Managing, S.L.U., ES-08184 Palau Solita / Plegamans

the right to use the **SKZ**-mark



**A 817**

for the following plastic products

**Heating pipes made of PE-RT Type II, with oxygen barrier,  
3- and 5-layer, dimension group 1 ( $d_n \leq 63$  mm)**

Structure	Dimension	Application class	
		4	5
3-layer	16 x 2.2 mm, 20 x 2.8 mm	10 bar	8 bar
3-layer	16 x 2.0 mm, 17 x 2.0 mm, 18 x 2.0 mm	8 bar	6 bar
3-layer	20 x 2.0 mm	6 bar	6 bar
3-layer	25 x 2.3 mm	6 bar	4 bar
5-layer	14 x 2.0 mm	8 bar	8 bar
5-layer	16 x 2.0 mm	8 bar	6 bar
5-layer	17 x 2.0 mm, 18 x 2.0 mm	6 bar	6 bar
5-layer	20 x 2.0 mm	6 bar	4 bar
5-layer	25 x 2.3 mm	4 bar	4 bar

according to **SKZ-Specification for Tests and Inspection HR 3.16:2024-02**.

Users of the **SKZ**-mark are obliged to observe the required regulations for the production and testing of these products.

Date of initial certification: 1 October 2020

Date of expiry: 10 November 2030

Würzburg, 11 November 2025



i. V.   
Dipl.-Ing. (FH) Michael Klute  
Deputy Head of Certification Body

The original language of this certificate is German. In case of doubt, the German version is obligatory.

SKZ - Testing GmbH, Friedrich-Bergius-Ring 22, 97076 Würzburg, Germany | Tel. +49 931 4104-0, testing@skz.de, www.skz.de  
The Certification Body of SKZ - Testing GmbH is accredited by DAkkS according to DIN EN ISO/IEC 17065:2013 under the number D-ZE-19033-01.