CERTIFICATE



SKZ - Testing GmbH awards the following company

Danfoss A/S Climate solutions Marsvej 5 6000 KOLDING DENMARK

Production site: Spain

the right to use the **SKZ**-mark



A 843

for the following plastic products

Heating pipes made of crosslinked polyethylene PE-Xa

Group 1 (≤ Ø 63 mm),
Application class 1, 2 and 4
Design pressure 10 bar
Application class 5
Design pressure 8 bar

Trade name: Danfoss Floor Heating Pipe

according to SKZ-Specification for Tests and Inspection HR 3.2:2015-04.

Users of the **SKZ**-mark are obliged to observe the required regulations for the production and

testing of these products.

Date of initial certification: ---

Date of expiry: 19 May 2027

Würzburg, 31 May 2023/

i.V. Sauch

Dipl.-Ing. Hans-Peter Krause Head of Certification Body

Certification Boo