## CERTIFICATE



**SKZ** - Testing GmbH awards the following company

Schütz GmbH & Co. KGaA Schützstraße 12 DE-56242 Selters

Production site: Schütz GmbH & Co. KGaA, DE-56235 Ransbach-Baumbach

the right to use the **SKZ**-mark



A 882

for the following plastic products

## Heating pipes made of PE-RT Type I or PE-RT Type II with oxygen barrier, 5-layer, dimension group 1 (d<sub>n</sub> ≤ 63 mm)

Dimension	Application class 4
14 x 1.5 mm, 16 x 1.5 mm, 20 x 1.9 mm, 20 x 2.0 mm, 25 x 2.3 mm	4 bar
12 x 1.5 mm, 16 x 1.8 mm, 16 x 2.0 mm, 17 x 2.0 mm, 18 x 2.0 mm	6 bar
14 x 2.0 mm, 16 x 2.2 mm	8 bar

Trade name: duo-flex PE-RT and duo-flex PE-RT Klett

according to SKZ-Specification for Tests and Inspection HR 3.16:2024-02.

Users of the **SKZ**-mark are obliged to observe the required regulations for the production and testing of these products.

Date of initial certification: 12 June 2025

Date of expiry: 11 June 2030

Würzburg, 12 June 2025

i. A.

Dipl.-Ing
Deputy

Michael Klube

Dipl.-Ing. (FH) Michael Klute
Deputy Head of Certification Body