

SKZ - Testing GmbH awards the following company

KAYALAR PRES DÖKÜM SAN.VE TİC.LTD.ŞTİ
Organize Sanayi Bölgesi Mahallesi. 8. Sokak. No: 7/1
TR-41455 Dilovası / Kocaeli

Production site: TR-34956 Tuzla / İstanbul

the right to use the SKZ-mark



A 910

for the following plastic products

**Heating pipes made of PE-RT Type II, with and without oxygen barrier,
 1-, 3- and 5-layer, dimension group 1 ($d_n \leq 63$ mm)**

Dimension		Application class	
		4	5
1-layer	14 x 2.0 mm	10 bar	8 bar
	16 x 1.8 mm, 17 x 2.0 mm, 20 x 2.3 mm	8 bar	6 bar
	16 x 2.0 mm	8 bar	8 bar
	20 x 2.0 mm	6 bar	6 bar
3-layer	14 x 2.0 mm	10 bar	8 bar
	16 x 1.8 mm, 16 x 2.0 mm, 17 x 2.0 mm, 20 x 2.3 mm	8 bar	6 bar
	20 x 2.0 mm	6 bar	6 bar
5-layer	14 x 2.0 mm	10 bar	8 bar
	16 x 1.8 mm, 17 x 2.0 mm, 20 x 2.3 mm	8 bar	6 bar
	16 x 2.0 mm	8 bar	8 bar
	20 x 2.0 mm	6 bar	6 bar

Trade name: KAS, BOTTI

according to SKZ-Specification for Tests and Inspection **HR 3.16:2024-02.**

Users of the SKZ-mark are obliged to observe the required regulations for the production and testing of these products.

Date of initial certification: 10 August 2026

Date of expiry: 9 August 2031

Würzburg, 10 August 2026



i. V.

Michael Klute

Dipl.-Ing. (FH) Michael Klute
 Deputy Head of Certification Body

The original language of this certificate is German. In case of doubt, the German version is obligatory.

SKZ - Testing GmbH, Friedrich-Bergius-Ring 22, 97076 Würzburg, Germany | Tel. +49 931 4104-0, testing@skz.de, www.skz.de

The Certification Body of SKZ - Testing GmbH is accredited by DAkkS according to DIN EN ISO/IEC 17065:2013 under the number D-ZE-19033-01.